

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 24/08/2026

It is certified that an inspection team headed by Mr. Sunil Kumar

(Name of Officers with designation) from Lab Chemist PHED

inspected the Kumaon Public School, Malli Mirai, Dwarahat (Almora)

(Name & Address of the school) on 21/08/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. One Sample Test Report dated 24/08/2026

of U.S. Jal Sansthan Lab, Mansi (PHED Lab) certified that

the Kumaon Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 month

TECHNICAL MANAGER

Sub-Divisional Level

Water Quality Testing

& Monitoring Laboratory

U.S. Jal Sansthan, Almora

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : U.S. Jal Sansthan

To

Kumaon Public School

Dwarahat (Almora)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Masi (Ranikhet) Almora
Phone No.: 05966-296077, E-mail: ujsmasirkt07@gmail.com
NABL ACCREDITED TESTING LABORATORY, CERTIFICATE No. : 01189

Test Report ID: 57 UJS/SDLWQTML/2026-27

Dated: 24/08/2026

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	KUMAON PUBLIC SCHOOL, DWARAHAT (ALMORA)		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description /Block Name	One Water Sample collected from Kumaon Public School, Dwarahat (RO Watert)/Dwarahat.
Reference Sample Identification:	SDLWQTML/UJS/EER-57		Date of Start of Analysis: 22/08/2026
			Date of End of Analysis: 24/08/2026
Date and Time of Sample Received: 21/08/26 & 11:25 AM	Sample Collected by:		Mr. Sanjay Bisht, Sampling Assistant

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.14	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/l	278	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.39	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/l	142	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/l	158	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	9.5	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/l	29.6	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/l	20.4	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	5	5	15	IS 3025 Pt-04 : 2021
10.	Iron, mg/l	0.02	1.0	No Relaxation	APHA23rd Ed.3500-Fe-B
11.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
12.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
Bacteriological Test Parameters					
13.	E-Coli, MPN/100ml	Absent	Absent	Absent	APHA 23rd Ed-9223 B
14.	Total Coliform, MPN/100ml	Absent	Absent	Absent	APHA 23rd Ed-9223 B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

TECHNICAL MANAGER
Sub-Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS, Ranikhet (Almora)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.